

Konnetti County Water District Hydrant Data Listed by Street Name

Street Name:	Street Number:	Cross Street or Location:	Distance Feet:	Direction:	Pressure Zone: 1=School Hill 2=Old Hill 3=Old	Hydrant Brand:	Hydrant Type:	Main Size Inch:	Shank Pressure:	Plant Grade Pressure:	Flow GPM:	Fire Dept. No.
Pine Ave.		Polk				Mueller	Dry Barrel	6"	80	40	1152	K001
Pine Ave.		Argonne Ave.				Amer. Darling	Dry Barrel	6"	76	60	1325	K002
Pine Ave.	4393					Amer. Darling	Dry Barrel	6"	78	60	1325	K003
Pine Ave.		Davis Ave.				Amer. Darling	Dry Barrel	6"	86	65	1503	K004
Argonne Ave.		Cedar Ave.				Amer. Darling	Dry Barrel	6"	56	43	1223	K005
Oak St.		Chateau				Mueller	Dry Barrel	6"				
Fir Ave.	3903	Chateau				Amer. Darling	Dry Barrel	6"	62	48	1292	K011
Eureka Ave.	3882					Greenburg	Worthead	8"	42	16	746	K016
Emile Ave.		Chateau				Jones	Worthead	4"				K020
Emile Ave.	3869	Davis Ave.	800'	N		Greenburg	Worthead	8"	58	8	527	K021
Cedar Ave.		Davis Ave.				Amer. Darling	Dry Barrel	6"	80	48	1220	K025
Cedar Ave.	4233	43rd Ave.				Amer. Darling	Dry Barrel	6"	92	65	1503	K026
Cedar Ave.		40th Ave.				Amer. Darling	Dry Barrel	6"	65	115	1999	K028
Fir Ave.		43rd Ave.				Amer. Darling	Dry Barrel	6"	70	64	1361	K032
Hemlock Ave.		40th Ave.				Amer. Darling	Dry Barrel	6"	100	65	1503	K037
Eureka Ave.		40th Ave.				Mueller	Dry Barrel	6"	80	74	1447	K042
Davis Ave.		Villa Ave.				Amer. Darling	Dry Barrel	8"	40	40	1179	K043
Phillips Ave.		45th Ave.				Mueller	Worthead	8"	52	18	791	K044
44th Ave.	15862	Phillips Ave.				Mueller	Dry Barrel	6"				K045
41st Ave		Phillips Ave.				Mueller	Dry Barrel	6"	40	24	906	K047
Davis Ave.	16010					Amer. Darling	Dry Barrel	8"	68	39	1164	K049
Irving Ave.		42nd Ave.				Amer. Darling	Dry Barrel	8"	60	34	1087	K050
Irving Ave.		40th Ave.				Amer. Darling	Dry Barrel	8"	58	33	1071	K051
Boyles Ave.		43rd Ave.				Mueller	Dry Barrel	6"	65	50	1234	K052

Konocti County Water District Hydrant Data Listed by Street Name											
Street Name:	Street Number:	Cross Street or Location:	Distance Feet:	Direction: From Job Location to Hydrant	Hydrant Brand:	Hydrant Type:	Main Size Pipe:	Apert. Pressure:	Test Gauge Pressure:	Flow (GPM):	Flow Dept. No.:
40th Ave.		Boyles Ave.			Mueller	Dry Barrel	6"	70	60	1325	K054
39th Ave		Irving Ave.	100	east	Mueller	Dry Barrel	6"	65	60	1325	K055
39th Ave		Oak St.			Mueller	Dry Barrel	6"	95	70	1412	K058
Pine Ave.		38th Ave.			Mueller	Dry Barrel	6"	105	84	1519	K059
Irving Ave.		38th Ave.			Amer. Darling	Dry Barrel	8"	75	43	1223	K062
38th Ave		Boyles Ave.			Greenburg	Worthead	4"				K063
Eureka Ave.		36th Ave.			Amer. Darling	Dry Barrel	8"	90	52	1344	K069
36th Ave.		Phillips Ave.			Amer. Darling	Dry Barrel	8"	90	52	1344	K070
36th Ave.		Irving Ave.			Amer. Darling	Dry Barrel	6"	82	47	1278	K071
Boyles Ave.		36th Ave.			Amer. Darling	Dry Barrel	8"	80	43	1223	K072
35th Ave.		Wilkinson	250	east	Mueller	Dry Barrel	6"	45	18	797	K075
35th Ave.		Konocti Ave.			Mueller	Dry Barrel	6"	82	38	1123	K077
35th Ave.	15813	Eureka Ave.		west	Amer. Darling	Dry Barrel	6"	80	42	1208	K081
Phillips Ave.		35th Ave.			Mueller	Worthead	6"	88	38	1149	K081
Crawford		34th Ave.			Mueller	Dry Barrel	6"				K082
Eureka Ave.		34th Ave.			Amer. Darling	Dry Barrel	8"	76	40	1179	K084
34th Ave	15884	Phillips Ave.			Mueller	Dry Barrel	6"	72	62	1343	K085
Boyles Ave.		34th Ave.			Amer. Darling	Dry Barrel	8"	74	38	1149	K087
Wilkinson		34th Ave.			Mueller	Dry Barrel	6"	52	40	1152	K089
32nd Ave.		Pine Ave.			Mueller	Worthead	8"	106	36	1119	K096
32nd Ave.		Oak St.			Mueller	Worthead	8"	96	34	1087	K097
Eureka Ave.		32nd Ave.			Amer. Darling	Dry Barrel	8"	87	47	1278	K098
32nd Ave.		Phillips Ave.			Mueller	Worthead	6"	70	20	834	K099

Kanetti County Water District Hydrant Data Listed by Street Name

Street Name:	Street Number:	Cross Street or Location:	Distance Feet:	Direction: Facing Side Back Side Corner	Hydrant Brand:	Hydrant Type:	Outlet Size:	Service Pressure:	Flow Capacity: GPM/FT	Flow GPM:	Fire Dept. No.:
Boyles Ave.		32nd Ave.			Mueller	Worthead	6"	62	20	834	K101
32nd Ave.		Konocti Ave.			Waterous	Dry Barrel	6"				K102
31st Ave.		Irving Ave.			Amer. Darling	Dry Barrel	6"	75	40	1179	K105
Pine Ave.		31st Ave.			Mueller	Dry Barrel	6"	105	52	1254	K109
Eureka Ave.		30th Ave.			Amer. Darling	Dry Barrel	8"	90	53	1357	K111
30th Ave		Phillips Ave.			Mueller	Dry Barrel	6"	67	40	1152	K112
30th Ave		Irving Ave.			Mueller	Dry Barrel	6"	62	45	1205	K113
30th Ave		Konocti Ave.			Mueller	Dry Barrel	6"	53	42	1171	K115
29th Ave.		Boyles Ave.			Amer. Darling	Dry Barrel	6"	23	64	1492	K116
29th Ave.		Phillips Ave.			Amer. Darling	Dry Barrel	6"	94	45	1251	K118
29th Ave.		Oak St.			Mueller	Dry Barrel	6"	95	44	1188	K120
28th Ave.		Pine Ave.			Mueller	Dry Barrel	6"	108	42	1171	K121
28th Ave.		Phillips Ave.			Mueller	Dry Barrel	6"	75	38	1123	K123
27th Ave.		Konocti Ave.			Mueller	Dry Barrel	6"	45	20	835	K127
27th Ave.		Irving Ave.			Mueller	Dry Barrel	6"	65	36	1093	K129
26th Ave.		Phillips Ave.			Amer. Darling	Dry Barrel	6"	100	42	1208	K132
Boyles Ave.		26th Ave.			Mueller	Worthead	6"	66	10	590	K134
26th Ave.		Boyles Ave.			Mueller	Dry Barrel	6"				K135
Wilkinson		26th Ave.			Mueller	Dry Barrel	6"	46	16	756	K136
Eureka Ave.		24th Ave.			Amer. Darling	Dry Barrel	8"	78	38	1149	K143
23rd Ave.		Garner Ave.			Amer. Darling	Dry Barrel	6"	96	40	1179	K148
23rd Ave.		Boyles Ave.			Amer. Darling	Dry Barrel	6"	86	27	969	K150
22nd Ave.		Oak St.			Mueller	Dry Barrel	6"	70	58	1308	K155
21st Ave.		Garner Ave.			Amer. Darling	Dry Barrel	6"	78	27	969	K159
21st Ave.		Boyles Ave.			Amer. Darling	Dry Barrel	6"	76	20	834	K161

Konoti County Water District Hydrant Data Listed by Street Name												
Street Name:	Street Number:	Cross Street or Location:	Distance Feet:	Direction:	Pressure Zone: 1=K184, 2=K185, 3=K188	Hydrant Brand:	Hydrant Type:	Main Size In:	Main Pressure:	Pipe Code Pressure:	Flow GPM:	Fire Dept. No.:
20th Ave.		Irving Ave.				Mueller	Dry Barrel	6"	52	42	1171	K165
Wilkinson		18th Ave.				Mueller	Dry Barrel	6"				K175
Boyles Ave.		18th Ave.				Mueller	Worthead	6"	60	10	590	K177
Irving Ave.		18th Ave.				Amer. Darling	Dry Barrel	6"				K178
18th Ave.		Garner Ave.				Mueller	Worthead	6"	65	10	590	K179
18th Ave.		Eureka Ave.				Amer. Darling	Dry Barrel	6"	74	14	698	K180
18th Ave.		Eureka Ave.				Mueller	Worthead	6"	74	8	527	K181
14th Ave.	16266					Jones	Worthead	4"	76	4	373	K184
13th Ave.		Boyles Ave.				Amer. Darling	Dry Barrel	6"				K185
Konoti Ave.		Dam Rd.				Mueller	Worthead	6"	125	18	791	K190
Cache Creek Apts		Dam Rd.				Amer. Darling	Dry Barrel	6"	100	72	1430	K193
Cache Creek Apts		Dam Rd.				Amer. Darling	Dry Barrel	6"	112	80	1498	K194
Cache Creek Apts		Dam Rd.				Amer. Darling	Dry Barrel	6"	120	86	1529	K195
Dam Rd.		Lake St.				Amer. Darling	Dry Barrel	6"	140	100	1630	K196
Dam Rd.	15950					Greenburg	Worthead	4"				K197
Davis Ave.		Manzanita Ave.				Amer. Darling	Dry Barrel	6"	102	65	1503	K200
Lane Ave.	4052	Davis Ave.				Mueller	Dry Barrel	6"	105	78	1481	K202
Spruce Ave.		Birch				Mueller	Dry Barrel	6"	118	44	1188	K204
Utah Ave.		Vallejo Ave.				Mueller	Dry Barrel	6"				K211
Highlands Ave.		Spruce Ave.				Mueller	Dry Barrel	6"	80	60	1325	K215
Highlands Ave.		Hale Ave.				Mueller	Dry Barrel	6"	86	60	1325	K216
Victor Ave.		Vallejo Ave.				Mueller	Dry Barrel	6"	80	54	1272	K220